

Tamil Nadu Generation and Distribution Corporation Ltd

(Technical Branch)

**144, Anna Salai,
Chennai-600 002.**

Memo.No.CE/Comml/SE/EE3/AEE2/F.15 mts. ht./D. 58 /18, dt. 01.03.2018.

Sub: TANGEDCO – Effecting of service connections to the building of more than 15 meters in height–Instructions issued - Reg.

Clarifications are being sought from the Chief Engineer/ Distributions regarding extension of supply to the buildings of more than 15 meters in height. In this connection it is clarified that,

As per DTCP regulation, Multi-Storied buildings means the building exceeding 4 Floors i.e the buildings including ground floor or if this ground is used for parking under stilts, stilt floor + 4 floors whose height is 15m or more.

Hence, the LT supply for Multi-Storied buildings of more than 15 meters in height at the voltage upto 650V” and HT supply for the electrical installations of voltage exceeding 650 Volts including Multi-Storied buildings of more than 15 meters in height shall be effected only after obtaining inspection certificate issued by the competent authority (inspection certificate from CEIG) in accordance with the G.O.(Ms)No.59 dt.14.08.2014 issued by the Government of Tamil Nadu. For other cases, the CEIG inspection certificate need not be insisted.

Receipt of the memo shall be acknowledged.

(By the order of the CMD/TANGEDCO)

Sd/-XXX XXX 01/03/2018.
Chief Engineer/Commercial
For Director/Distribution

To
All the Chief Engineer’s/Distribution/Regions.
Copy to all the Superintending Engineer’s/EDC’S (By E.Mail)